

### Environmental Protection Licence Monitoring Data

**Project Name:** WestConnex - M8  
**Licensee:** WCX M5 PT PTY LTD  
**Monitoring Period:** 1/11/2023 - 30/11/2023  
**Website:** [www.westconnex.com.au/NewM5Environment](http://www.westconnex.com.au/NewM5Environment)  
**Environmental Protection Licence:** 21351  
**Premise Address:** Operational Water Treatment Plant M8 - Motorway Operations Complex 3 Arncliffe NSW 2205



**Monitoring Type:**

| Sample Date     | Discharge/Monitoring Point  | Sampling Method |
|-----------------|-----------------------------|-----------------|
| 8 November 2023 | Water Treatment Plant ARN-2 | Grab Sample     |

| General   |         |                 |         | Metals (µg/L) |        |        |        |        |        |           |        |        |        | Total Recoverable Hydrocarbons |        |         |        |         |        |
|-----------|---------|-----------------|---------|---------------|--------|--------|--------|--------|--------|-----------|--------|--------|--------|--------------------------------|--------|---------|--------|---------|--------|
| pH        |         | Turbidity (NTU) |         | Aluminium     |        | Cobalt |        | Copper |        | Manganese |        | Zinc   |        | C10-C16                        |        | C16-C34 |        | C34-C40 |        |
| Limit     | Results | Limit           | Results | Limit*        | Result | Limit* | Result | Limit* | Result | Limit*    | Result | Limit* | Result | Limit*                         | Result | Limit*  | Result | Limit*  | Result |
| 6.5 - 8.5 | 7.62    | 25              | 1.4     | 600           | 530    | 8.0    | 1.0    | 10.3   | 1.0    | 10600     | 155    | 150    | 5.0    | <100                           | <100   | <100    | <100   | <100    | <100   |

**Key**

\*90th percentile concentration limit