

**Environmental Protection Licence Monitoring Data**

**Project Name:** WestConnex - M8  
**Licensee:** WCX M5 PT PTY LTD  
**Monitoring Period:** January 2025  
**Website:** [www.westconnex.com.au/NewMSEenvironment](http://www.westconnex.com.au/NewMSEenvironment)  
**Environmental Protection Licence:** 21351  
**Premise Address:** Operational Water Treatment Plant M8 - Motorway Operations Complex 3 Arncliffe NSW 2205  
**Discharge/Monitoring Point:** M8 Water Treatment Plant  
**Sampling Method:** Grab Sample



Date	General				Metals (µg/L)								Total Recoverable Hydrocarbons						Compliant		
	pH		Turbidity (NTU)		Aluminium		Cobalt		Copper		Manganese		Zinc		C10-C16		C16-C34			C34-C40	
	Limit	Results	Limit	Results	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result		Limit*	Result
6/01/2025	6.5 - 8.5	7.10	25	3.6	600	60	8.0	1	10.3	1	10600	370	150	10	<100	<100	<100	<100	<100	<100	Yes
14/01/2025		7.46		2.8		60		1		1		569		10	<100	<100	<100	<100	<100	<100	Yes

\*90th percentile concentration limit specified by EPL 21351