

**Environmental Protection Licence Monitoring Data**



**Project Name:** WestConnex - M8  
**Licensee:** WCX M5 PT PTY LTD  
**Monitoring Period:** 1/08/2024 - 31/08/2024  
**Website:** [www.westconnex.com.au/NewM5Environment](http://www.westconnex.com.au/NewM5Environment)  
**Environmental Protection Licence:** 21351  
**Premise Address:** Operational Water Treatment Plant M8 - Motorway Operations Complex 3 Arncliffe NSW 2205

Sample Date		Discharge/Monitoring Point										Sampling Method							
8/1/2024		Water Treatment Plant ARN-2										Grab Sample							
General				Metals (µg/L)										Total Recoverable Hydrocarbons					
pH		Turbidity (NTU)		Aluminium		Cobalt		Copper		Manganese		Zinc		C10-C16		C16-C34		C34-C40	
Limit	Results	Limit	Results	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result
6.5 - 8.5	7.10	25	16.2	600	10	8.0	1.0	10.3	4.0	10600	1030	150	5.0	<100	<100	<100	<100	<100	<100

**Key**

\*90th percentile concentration limit specified by EPL 21351