

Environmental Protection Licence Monitoring Data

Project Name: WestConnex - M8
Licensee: WCX M5 PT PTY LTD
Monitoring Period: December 2024
Website: www.westconnex.com.au/NewM5Environment
Environmental Protection Licence: 21351
Premise Address: Operational Water Treatment Plant M8 - Motorway Operations Complex 3 Arncliffe NSW 2205



Sample Date		Discharge/Monitoring Point										Sampling Method							
4/12/2024		Water Treatment Plant ARN-2										Grab Sample							
General				Metals (µg/L)								Total Recoverable Hydrocarbons							
pH		Turbidity (NTU)		Aluminium		Cobalt		Copper		Manganese		Zinc		C10-C16		C16-C34		C34-C40	
Limit	Results	Limit	Results	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result
6.5 - 8.5	6.86	25	8.6	600	10	8.0	1	10.3	1	10600	550	150	50	<100	<100	<100	<100	<100	<100

*90th percentile concentration limit specified by EPL 21351